

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 163Date: 19/05/2026

It is certified that an inspection team headed by Md. Amiruddin Ansari
Assistant Engineer (Name of Officers
with designation) from P. H. Sub. Division Rajgarh Nalanda (Name of
Department/Office) inspected the Mother Teressa High School
Chorsua, Paesapur, Nalanda. (Name & Address of
the School) on 19/5/26 and found that the Mother Teressa
High School Chorsua, Paesapur Nalanda (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.Signature with Seal : [Signature]

Name

: Md. Amiruddin Ansari

Designation

: Assistant Engineer

भर प्रमडल पदाधिकारी

लोक स्वास्थ्य अतर प्रमडल

राजगौर (नालन्दा)

To

Mother Teressa High
School, Chorsua, Paesapur
Nalanda -

(Name & Address of the Institution)

Government of Bihar
Public Health Engineering Department
Water Quality Report

District Name: Nalanda

Division Name: Public Health Engineering Division, Biharsharif & Hilsa

Sample Collected by : - Ref no-MT/CH/029/2026-27 DATE-18.5.26 AMRIT KUMAR

Date of Sampling :- 18/05/2026

| Sl. No. | Block | Panchayat | Village | Habitation | Location of Source | Test result | | | | | | | | | | | | | | Source of Water |
|---|---------|-----------|---------|------------|----------------------------|-------------|-------|-----|------|-----|-----|-----|------|-------|------|-----------------|-----------------|-------|-----------|-----------------|
| | | | | | | pH | Turb. | EC | TDS | TH | Ca | Mg | Cl | Alka. | Fe | NO ₃ | SO ₄ | F | | |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | |
| 1 | GIRIYAK | CHORSUA | CHORSUA | PAWAPURI | MOTHER TERESSA HIGH SCHOOL | 7.88 | 0.52 | 442 | 287 | 130 | 32 | 12 | 40 | 140 | 0.14 | <1.0 | 10.5 | 0.564 | Tap water | |
| Desirable Limit | | | | | | 6.5-8.5 | 1 | - | 500 | 200 | 75 | 30 | 250 | 200 | 1 | 45 | 200 | 1 | - | |
| Permissible Limit* In absence of alternate source | | | | | | NR | 5 | - | 2000 | 600 | 200 | 100 | 1000 | 600 | NR | NR | 400 | 1.5 | - | |

Chemist
Public Health Division, Biharsharif
(Nalanda)

(Signature)
18/05/2026